



SUPPLEMENTAL BID BULLETIN NO. 2024 - 11

FOR THE

**SUPPLY AND DELIVERY OF KILOWATT-HOUR METERS WITH
METER BASE (CONSIGNMENT BASIS)**

This addendum is issued to amend items in the Bidding Documents. This shall form an integral part of the Bidding Documents for the above-captioned project.

1. Page 51 of Section VIII. Terms of Reference (Lot 1) KWH Meter, 1 phase, Class 100, 2W, 240V, Form 1S, Socket Type, Technical Specification, Item 1, LCD Display:

REQUIREMENT	ADDENDUM
LCD Display: Minimum of 0.75-inch size display.	LCD Display: Minimum of 0.50-inch size or 12.7 millimeters.

For guidance and information of all concerned.

Issued this 1st day of October 2024 at Del Rosario, Naga City, Philippines.


ENGR. MARY FRANCE D. MORALES
Chairman, Bids and Awards Committee

Noted by:


ENGR. EDGARDO R. PIAMONTE
Acting General Manager



Districts:

•Naga South •Naga North •Pili •Milaor •Minalabac •Canaman •Magarao •Bombon •Calabanga •Tinambac •Siruma